

**IEC****IECEE**  
CB  
SCHEME

Ref. Certif. No.

**SE-67418A1**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST  
CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEMESYSTEME CEI D'ACCEPTATION MUTUELLE DE  
CERTIFICATS D'ESSAIS DES EQUIPEMENTS  
ELECTRIQUES (IECEE) METHODE OC**CB TEST CERTIFICATE****CERTIFICAT D'ESSAI OC**Product  
Produit

Circuit breakers

Name and address of the applicant  
Nom et adresse du demandeurLEGRAND SNC.  
128 avenue du Maréchal de Lattre, de Tassigny.  
FR-87045 Limoges cedex, FRANCEName and address of the manufacturer  
Nom et adresse du fabricantBTICINO SpA -Legrand Group.  
Via Messina 38, IT-20154 Milano.  
ITALYName and address of the factory  
Nom et adresse de l'usine  
Note: When more than one factory, please report on page 2  
Note: Lorsque il y plus d'une usine, veuillez utiliser la 2<sup>ème</sup>BTICINO SpA -Legrand Group.  
Via Folzoni 5, 24052 Azzano San Paolo, Bergamo.  
ITALYRatings and principal characteristics  
Valeurs nominales et caractéristiques principales $U_e = 220 - 690V AC$ ,  $I_n = 40 - 250A$ , 50-60Hz.  
Pattern No 3 and 4.  
 $U_i = 800V$ ,  $U_{imp} = 8kV$ . See also page 2.Trademark (if any)  
Marque de fabrique (si elle existe)

Legrand

Type of Manufacturer's Testing Laboratories used  
Type de programme du laboratoire d'essais  
constructeur

WMT

Model / Type Ref.  
Ref. De typeDPX<sup>3</sup> 250 B electronic, DPX<sup>3</sup> 250 F electronic, DPX<sup>3</sup> 250 N  
electronic and DPX<sup>3</sup> 250 H electronicAdditional information (if necessary may also be  
reported on page 2)  
Les informations complémentaires (si nécessaire,  
peuvent être indiqués sur la 2<sup>ème</sup> page)This certificate replaces CB-certificate SE-67418, dated 8  
December 2011. A new certificate is issued due to a misprint of  
the standard on the certificate.A sample of the product was tested and found  
to be in conformity with  
Un échantillon de ce produit a été essayé et a été  
considéré conforme à la


IEC 60947-2:2006 and A1

As shown in the Test Report Ref. No. which forms part  
of this Certificate  
Comme indiqué dans le Rapport d'essais numéro de  
référence qui constitue partie de ce Certificat

1117386

This CB Test Certificate is issued by the National Certification Body  
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**Intertek Semko AB  
Box 1103  
SE-164 22 Kista, Sweden  
Int +46 8 750 00 00**Intertek**

Date: 21 May 2012

Signature: 

Bo Berglöf



Additional information (if necessary)  
Information complémentaire (si nécessaire)

DPX<sup>3</sup> 250H electronic

Ue (V)	Icm (kA)	Icu (kA)	Ics (kA)
240	220	100	100
415	154	70	70
440	132	60	60
500	84	40	40
690	40	20	20

DPX<sup>3</sup> 250B electronic

Ue (V)	Icm (kA)	Icu (kA)	Ics (kA)
240	84	40	40
415	52,5	25	25
440	40	20	20
500	17	10	10
690	13,6	8	8

DPX<sup>3</sup> 250F electronic

Ue (V)	Icm (kA)	Icu (kA)	Ics (kA)
240	132	60	60
415	75,6	36	36
440	63	30	30
500	52,5	25	25
690	32	16	16

DPX<sup>3</sup> 250N electronic

Ue (V)	Icm (kA)	Icu (kA)	Ics (kA)
240	176	80	80
415	105	50	50
440	84	40	40
500	63	30	30
690	36	18	18

Date: 21 May 2012

Signature: 